



## WESTFARMS GENERAL INFORMATION

### Landlord's Tenant Coordinator

The role of the Tenant Coordinator is to serve as liaison between Landlord and the Tenant, Tenant's architect and Tenant's contractor. All plans and correspondence concerning Tenant's construction are to be submitted to the Landlord's Tenant coordination Department.

Tenant Coordination  
Westfarms

**Jennifer Grider, Tenant Coordinator**  
200 East Long Lake Road, Suite 300  
Bloomfield Hills, MI 48304-0200

**Direct Phone: (248) 258-7396**

Email: [jgrider@taubman.com](mailto:jgrider@taubman.com)

### Mall Address

Westfarms  
Management Office  
500 Westfarms Mall  
Farmington, CT 06032-2692

**Facilities Director – Michael Gonsalves**

**Phone: (860) 561-3420 x2118**

### Building Information

**Construction Type:** 2B Unprotected/Fully Sprinkled

**Zoning Classification:** Mercantile

### Building Heights

First to Second Floor: 16'-6", Clear Height to underside of structure: +/- 14'-0"  
Second Floor to Roof: 17'-6", Clear height to underside of structure: +/- 14'-0"  
Allowable Ceiling Height: 11'-6"

### Floor Construction

First Floor: 4" concrete slab with a minimum strength of 3,000 psi reinforced with 6" X 6" W2.9 X W2.9 wwm in upper 1/3 of concrete on vapor barrier (10 mil minimum)  
Second Floor: 4" concrete over metal decking at B and C Buildings. 8" precast concrete planks with 2" topping at D, E, F and H Buildings.  
Design Load: First and Second levels, 75 lbs/sf live load + 20 lbs/sf for partitions.  
Roof, 20 lbs/sf maximum

### Demising Wall Construction

One layer 5/8" gypsum board tenant side only on 4" metal studs @ 16" OC (25 gauge)

# Westfarms

## Service Corridor Vestibule Required

Yes

One layer of 1/2" fire-retardant treated plywood 4'-0" high with 4" metal corner guards 8' high to be installed inside service vestibule recess to match Landlord corridor finish.

## Utility Services and Points of Connection

Electrical: Service available to premises: 277/480 volt, 3 phase 4 wire, 60 hertz.

Watt Density: Retail Tenants: 6.0 watts/SF  
Food Service Tenants: 40.0 watts/SF

Tenants with electrical service requirements of **less** than 200 amps connect to tenant distribution centers located in close proximity as determined by Landlord at Tenant expense.

Tenants with service requirements **greater** than 200 amps connect to electrical service equipment in nearest electrical distribution room to Tenants premises as determined by Landlord at Tenant expense.

## Telephone

Tenant to extend telephone service in conduit from premises to Landlord's designated telephone closet as determined by Landlord at Tenant's expense.

## Plumbing

3/4" Cold Water stub located **above** the premises for first floor tenant's and **below** the floor for second floor tenants, in a location determined by Landlord. Location of larger size stubs must be verified in field and at Tenants expense.

4" Sanitary Sewer and Plumbing Vent stubbed to a location determined by Landlord.

Gas Utility Company meter manifolds locations as determined by Landlord.

**All tenants are to provide a full set of mechanical documents for the project to the cross connection Department of the local water supplier, the address follows.**

**The Metropolitan District  
James McDonald  
555 Main Street, P.O. Box 800  
Hartford, CT 06142-0800**

## HVAC

B & C Buildings

VAC Conditioned Air Supply stubbed to a location within or in close proximity to tenant's premises. VAV boxes will be provided to the tenant by Landlord in accordance with the Landlord approved construction documents.

B&C buildings return air is through ceiling plenum. Open ceilings must have duct return through the premises.

Maximum CFM for tenants on the First Floor: = 1.20 CFM/SF

Maximum CFM for tenants on the Second Floor: = 1.30 CFM/SF

Lighting: 6.5 watts/SF

Occupancy: One Person/75 SF

# Westfarms

D, E, F & H Buildings

Tenant must provide an individual air system designed with spring isolators, installed in tenant's space independent of Landlord's structure. Air cooled condensing equipment will be located on structural steel support rails with spring isolators on the roof.

Return air is through ducted returns.

All tenant HVAC equipment, make up air systems, exhaust fans, etc., to be located on the roof must be installed on structural steel support rails or equipment curbs on spring isolators located on the roof in locations determined by Landlord.

## **Fire Protection**

Sprinkler system is a hydraulically calculated fire protection system.

Submit drawings for review to the local Fire Department.

B & C Building: One interface module, horn and strobe furnished by Tenant.

## **Smoke detectors required**

Yes, Smoke control occurs in common area and through tenant ceiling plenums.

## **Toilet Facility requirements**

One employee toilet is required in all tenant spaces.

Tenant spaces with employee occupancy greater than 15 people must provide a separate toilet for each gender.

## **Exiting Requirements**

One exit required in tenant spaces less the 1500 sf and with an occupancy load less than 50.

All other spaces require a minimum of two exits.

## **CONSTRUCTION PREREQUISITES**

Please refer to the Construction Rules and Regs